Heckington St Andrew's Church of England Primary School Accessibility Audit

Updated September 2016

Reviewed annually

We believe that this Accessibility Plan is compliant with current legislation and requirements as specified in Schedule 10, relating to Disability, of the Equality Act 2010. School Governors are accountable for implementation, review and reporting on progress of the Accessibility Plan over a prescribed period.

- Heckington St Andrew's Accessibility Plan has been drawn up in conjunction with staff and governors of the school and will advise other school planning documents. The Accessibility Plan will be reported upon annually in respect of progress and outcomes and provide a projected plan for the four year period ahead of the next review date. This plan was updated in October 2014.
- The Accessibility Plan is structured to complement and support the school's Equality objectives, and will similarly be published on the school website.
- We are committed to providing an environment that enables full curriculum access that values and includes all pupils, staff, parents/carers and visitors regardless of their education, physical, sensory, social, spiritual, emotional and cultural needs. We are committed to taking positive action in the spirit of the Equality Act 2010 with regard to disability and to developing a culture of inclusion, support and awareness within the school.
- The Accessibility Plan shows how access is to be improved for disabled pupils, staff and visitors to the school in a given timeframe and anticipating the need to make reasonable adjustments to accommodate their needs where practicable. The Accessibility Plan contains relevant and timely action to:
 - Increase access to the curriculum for pupils with a disability, expanding the curriculum as necessary to ensure that pupils with a disability are as, equally, prepared for life as are the able-bodied pupils; (if a school fails to do this they are in breach of duties under the Equalities Act 2010); this covers teaching and learning and the wider curriculum of the school such as participation in after-school clubs, leisure and cultural activities or school visits it also covers the provision of specialist or auxiliary aids and equipment, which may assist these pupils in accessing the curriculum in a reasonable timeframe.
 - Improve access to the physical environment of the school, adding specialist facilities as necessary this covers improvements to the physical environment of the school and physical aids to access education within a reasonable timeframe.
 - Improve the delivery of written information to pupils, staff, parents/carers and visitors with disabilities; examples might include letters, textbooks and information about the school and school events; the information should be made available in various preferred formats with a reasonable timeframe.
- The Accessibility Plan relates to the key aspects of physical environment, curriculum and written information.

- Whole school training will recognise the need to continue raising awareness for staff and governors on equality issued with reference to the Equality Act 2010.
- The accessibility Plan should be read in conjunction with the following school policies, strategies and documents:
 - Curriculum Policy
 - Equal Opportunities Policy
 - Health & Safety Policy
 - Special Education Needs Policy
 - Behaviour Policy
 - School Improvement Plan
 - Asset Management Plan/Suitability Survey
 - School Prospectus
- The Accessibility Plan for physical accessibility relates to the Access Audit of the School, which remains that
 responsibility of the Governing Body. It may not be feasible to undertake all of the works during the life of this
 Accessibility Plan and therefore some items will roll forward into subsequent plans. An accessibility audit will be
 completed by the school prior to the end of each period covering this plan in order to inform the development of a new
 Accessibility Plan for the ongoing period.
- Equality Impact Assessments will be undertaken as and when school policies are reviewed. The terms of reference for all governors' committees will include the need to consider Quality and Diversity issues as required by the Equality Act 2010.
- The Accessibility Plan will be published on the school website.
- The Accessibility Plan will be monitored by the 'Finance, Premises and Personnel Committee'. (FPP)
- The school will work in partnership with the Local Authority and the Diocese of Lincoln in developing and implementing this Accessibility Plan.
- The Accessibility Plan may be monitored by Ofsted during Inspection processes in relation to Schedule 10 of the Equality Act 2010.

| Are suitable and sufficient identified parking bays provided for disabled people? Yes, disabled parking bay outside school entrance door, clearly marked. Should be less than 50m from entrance) ite there a kerb surrounding the car park? Yes Is there a kerb surrounding the car park? Yes Yes If 'ryes', is there a ramp or dropped kerb? Yes Yes Is the approach between car park/pavement and entrance free of obstacles? Yes Yes If 'no', please specify the obstacle. For example, loose paving, bollards, signs, benches, surface finish, drains, gravel, etc. N?A ENTERING MAIN BUILDING Result and Recommendation No ENTERNCE DOORS Result and Recommendation N/A If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height If 'yes', other yremain open long enough for a slow moving person to pass though easily? Yes Yes If there are manual doors, are they easy to open? N/A Yes Ob they remain open during entry? Yes Yes Are handles at wheelchair-user height? Yes Yes Ob they remain open during entry? Yes Yes Are handles at wheelchair-user be opple approaching from the doo | PARKING AND EGRESS | Result and Recommendation |
|--|---|---|
| (Should be less than 50m from entrance) Yes Is there a kerb surrounding the car park? Yes Is the approach between car park/pavement and entrance free of obstacles? Yes Is the approach between car park/pavement and entrance free of obstacles? Yes If 'no', please specify the obstacle. For example, loose paving, bollards, signs, benches, surface finish, drains, gravel, etc. N?A Is there adquate access to the sports field and playground? Yes – all on one level ENTERING MAIN BUILDING Result and Recommendation Is there a suitable tramp (If levels require it) to Main Entrance? N/A EITRANCE DOORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height outwards lif 'yes,' do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Outwards If the doors wide enough to allow an easy wheelchair manoeuvre? Yes Yes (435cm above floor level) Yes Yes Yes Are the doors and beelchair-user to see people approaching from the other side? (Clear visibility between 90cm and 150cm above floor level) N/A | Are suitable and sufficient identified parking bays provided for disabled | Yes, disabled parking bay outside school entrance door, |
| is there a kerb surrounding the car park? Yes If 'yes', is there a ramp or dropped kerb? Yes Is the approach between car park/paverment and entrance free of obstacles? Yes if 'no', please specify the obstacle. For example, loose paving, bollards, signs, benches, surface finish, drains, gravel, etc. N?A is there a dequate access to the sports field and playground? Yes – all on one level ENTERING MAIN BUILDING Result and Recommendation Is there a suitable ramp (if levels require it) to Main Entrance? Not required If on, is there a suitable alternative entrance for individuals with mobility difficulties? NA ENTRANCE DORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height Obes the building have automatic doors? No, push button, button at wheel chair height? Yes If 'yes,' do they remain open long enough for a slow moving person to pass though easily? Yes Yes If there are manual cloors, are they easy to open? N/A Yes Are handles at wheelchair-user height? Yes Yes (135cm above floor level) Yes Yes Are thandoors anale wheelchair user height? Yes< | people? | clearly marked. |
| If yes', is there a ramp or dropped kerb? Yes Is the approach between car park/pavement and entrance free of obstacles? Yes If 'no', please specify the obstacle. For example, loose paving, bollards, signs, benches, surface finish, drains, gravel, etc. N?A Is there adequate access to the sports field and playground? Yes – all on one level ENTERING MAIN BUILDING Result and Recommendation Is there a suitable ramp (if levels require it) to Main Entrance? Not required If noi, is there a suitable alternative entrance for individuals with mobility difficulties? Not required ENTRANCE DOORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height Obs the building have automatic doors? No, push button, button at wheel chair height outwards If yes, 'do they remain open long enough for a slow moving person to pass though easily? Yes Yes If there are manual doors, are they easy to open? N/A N/A Do they remain open during entry? Yes Yes (If score above floor level) Yes Second and 168cm for double doors) Do the doors anable wheelchair-users to see people approaching from the other side? (Clear visibility between 90cm and | | |
| Is the approach between car park/pavement and entrance free of obstacles? Yes I' no', please specify the obstacle. For example, loose paving, bollards, signs, benches, surface finish, drains, gravel, etc. N?A Is there adequate access to the sports field and playground? Yes – all on one level ENTERING MAIN BULDING Result and Recommendation Is there a suitable ramp (if levels require it) to Main Entrance? Not required I' not, is there a suitable atternative entrance for individuals with mobility difficulties? N/A ENTRING doors op outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height If 'yes, 'which way do they open? outwards Yes I's there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Other doors one and l68cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the door? Yes (115cm above floor level) N/A The handles at wheelchair-users to see people approaching from the doors? Yes (135cm above floor level) N/A The doors are | Is there a kerb surrounding the car park? | |
| obstacies? N?A If 'no', please specify the obstacle. For example, loose paving, bollards, signs, benches, surface finish, drains, gravel, etc. N?A Is there adequate access to the sports field and playground? Yes – all on one level ENTERING MAIN BUILDING Result and Recommendation Is there a suitable ramp (if levels require it) to Main Entrance? Not required If not, is there a suitable alternative entrance for individuals with mobility difficulties? N/A ENTRANCE DOORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height Does the building have automatic doors? No, push button, button at wheel chair height Yes If yes,' do they open? Outwards Yes Do they remain open long enough for a slow moving person to pass though easily? Yes Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do the cores enable wheelchair-users to see people approaching from the door? N/A <td>If 'yes', is there a ramp or dropped kerb?</td> <td>Yes</td> | If 'yes', is there a ramp or dropped kerb? | Yes |
| signs, benches, surface finish, drains, gravel, etc. Yes – all on one level Is there adequate access to the sports field and playground? Yes – all on one level ENTERING MAIN BUILDING Result and Recommendation Is there a suitable ramp (if levels require it) to Main Entrance? Not required If not, is there a suitable alternative entrance for individuals with mobility difficulties? N/A ENTERING or sopen outwards, is there enough space for them to open without obstructing passage of wheelchair? N/A Does the building have automatic doors? No, push button, button at wheel chair height If yes, do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Ob they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do the yer enain open during entry? Yes (1stor s are enainly glass, is there clear identification warning on the door? N/A Do the doors are mainly glass, is there clear identification warning on the door? N/A If there | | Yes |
| ENTERING MAIN BUILDING Result and Recommendation Is there a suitable ramp (if levels require it) to Main Entrance? Not required If not, is there a suitable alternative entrance for individuals with mobility difficulties? N/A ENTRANCE DOORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height Does the building have automatic doors? No, push button, button at wheel chair height If yes, 'which way do they open? outwards If yes, 'do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are thandles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (24cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the door? N/A If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. | | N?A |
| ENTERING MAIN BUILDING Result and Recommendation Is there a suitable ramp (if levels require it) to Main Entrance? Not required If not, is there a suitable alternative entrance for individuals with mobility difficulties? N/A ENTRANCE DOORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? No, push button, button at wheel chair height Does the building have automatic doors? No, push button, button at wheel chair height If yes, 'which way do they open? outwards If yes, 'do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are thandles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (24cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the door? N/A If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. | Is there adequate access to the sports field and playground? | Yes – all on one level |
| If not, is there a suitable alternative entrance for individuals with mobility N/A difficulties? N/A ENTRANCE DOORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open Yes without obstructing passage of wheelchair? No, push button, button at wheel chair height Does the building have automatic doors? No, push button, button at wheel chair height If 'yes, 'which way do they open? outwards If sy, 'do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (B4cm for single door and 168cm for double doors) Yes Do they crear anianly glass, is there clear identification warning on the other single glass, is there clear identification warning on the doors? N/A If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. No. Is it of suitable height for a wheelchair u | | Result and Recommendation |
| If not, is there a suitable alternative entrance for individuals with mobility N/A difficulties? N/A ENTRANCE DOORS Result and Recommendation If entrance doors open outwards, is there enough space for them to open Yes without obstructing passage of wheelchair? No, push button, button at wheel chair height Does the building have automatic doors? No, push button, button at wheel chair height If 'yes, 'which way do they open? outwards If sy, 'do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (B4cm for single door and 168cm for double doors) Yes Do they crear anianly glass, is there clear identification warning on the other single glass, is there clear identification warning on the doors? N/A If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. No. Is it of suitable height for a wheelchair u | Is there a suitable ramp (if levels require it) to Main Entrance? | Not required |
| If entrance doors open outwards, is there enough space for them to open without obstructing passage of wheelchair? Yes Does the building have automatic doors? No, push button, button at wheel chair height If 'yes,' which way do they open? Outwards If yes,' do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do they doors enable wheelchair-users to see people approaching from the doors? Yes If the doors are mainly glass, is there clear identification warning on the door? N/A If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. No. Is it of suitable height for a wheelchair user? Yes Yes | If not, is there a suitable alternative entrance for individuals with mobility | |
| without obstructing passage of wheelchair? No, push button, button at wheel chair height Does the building have automatic doors? No, push button, button at wheel chair height If 'yes,' which way do they open? outwards If yes,' do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the doors? N/A If the doors are mainly glass, is there clear identification warning on the door? N/A If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. No. Is there is a waiting area, is it suitably large and laid out for wheelchair weekehair user? Yes | ENTRANCE DOORS | Result and Recommendation |
| Does the building have automatic doors?No, push button, button at wheel chair heightIf 'yes,' which way do they open?outwardsIf yes,' do they remain open long enough for a slow moving person to pass though easily?YesIf there are manual doors, are they easy to open?N/ADo they remain open during entry?YesAre handles at wheelchair-user height?Yes(135cm above floor level)YesAre the doors wide enough to allow an easy wheelchair manoeuvre?Yes(84cm for single door and 168cm for double doors)YesDo they remainly glass, is there clear identification warning on the door?N/AIf there is a reception desk/facility in this building, is it clearly and logically placed?YesIs there adequate provision for the hearing impaired.No.Is it of suitable height for a wheelchair user?YesYesYesSit of suitable height for a wheelchair user?YesYesYes | | Yes |
| If 'yes,' which way do they open? outwards If yes,' do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do they create at mainly glass, is there clear identification warning on the doors are mainly glass, is there clear identification warning on the door? N/A ISIDE THE BUILDING Result and Recommendation Yes If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Yes Is it of suitable height for a wheelchair user? Yes Yes If there is a waiting area, is it suitably large and laid out for wheelchair user? Yes Yes | | No, push button, button at wheel chair height |
| If 'yes,' do they remain open long enough for a slow moving person to pass though easily? Yes If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the other side? (Clear visibility between 90cm and 150cm above floor level) Yes If the doors are mainly glass, is there clear identification warning on the door? N/A INSIDE THE BUILDING Result and Recommendation If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair user? Yes | | |
| If there are manual doors, are they easy to open? N/A Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the other side? (Clear visibility between 90cm and 150cm above floor level) Yes If the doors are mainly glass, is there clear identification warning on the door? N/A INSIDE THE BUILDING Result and Recommendation If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair user? Yes | If 'yes,' do they remain open long enough for a slow moving person to | |
| Do they remain open during entry? Yes Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the other side? (Clear visibility between 90cm and 150cm above floor level) Yes If the doors are mainly glass, is there clear identification warning on the door? N/A INSIDE THE BUILDING Result and Recommendation If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair user? Yes | | N/A |
| Are handles at wheelchair-user height? Yes (135cm above floor level) Yes Are the doors wide enough to allow an easy wheelchair manoeuvre? Yes (84cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the other side? (Clear visibility between 90cm and 150cm above floor level) Yes If the doors are mainly glass, is there clear identification warning on the door? N/A INSIDE THE BUILDING Result and Recommendation If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair user? Yes. | | Yes |
| Are the doors wide enough to allow an easy wheelchair manoeuvre? (84cm for single door and 168cm for double doors) Yes Do the doors enable wheelchair-users to see people approaching from the other side? (Clear visibility between 90cm and 150cm above floor level) Yes If the doors are mainly glass, is there clear identification warning on the door? N/A INSIDE THE BUILDING Result and Recommendation If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair users? Yes | Are handles at wheelchair-user height? | Yes |
| other side? (Clear visibility between 90cm and 150cm above floor level)If the doors are mainly glass, is there clear identification warning on the door?N/AINSIDE THE BUILDINGResult and RecommendationIf there is a reception desk/facility in this building, is it clearly and logically placed?YesIs there adequate provision for the hearing impaired.No.Is it of suitable height for a wheelchair user?YesIf there is a waiting area, is it suitably large and laid out for wheelchair users?Yes. | | Yes |
| door? Result and Recommendation INSIDE THE BUILDING Result and Recommendation If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair user? Yes. | | Yes |
| If there is a reception desk/facility in this building, is it clearly and logically placed? Yes Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair user? Yes. users? Yes. | If the doors are mainly glass, is there clear identification warning on the | N/A |
| placed? No. Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair users? Yes. | INSIDE THE BUILDING | Result and Recommendation |
| placed? No. Is there adequate provision for the hearing impaired. No. Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair users? Yes. | If there is a reception desk/facility in this building, is it clearly and logically | Yes |
| Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair users? Yes. | | |
| Is it of suitable height for a wheelchair user? Yes If there is a waiting area, is it suitably large and laid out for wheelchair users? Yes. | Is there adequate provision for the hearing impaired. | No. |
| users? | | Yes |
| Are all internal floors level throughout? Yes | If there is a waiting area, is it suitably large and laid out for wheelchair | Yes. |
| | Are all internal floors level throughout? | Yes |

| Is the floor surface free of any access or tripping hazard? | Yes. |
|--|---|
| Is any information available in reception and on website, suitable for those | Website meets accessibility requirements |
| with visual impairment? | |
| Is there a good contrast of colour to assist access for the visually | No |
| impaired? | |
| Is the lighting adequate? | Yes |
| Is there a hearing aid loop installed within the building | No |
| IN THE CORRIDOR | Result and Recommendation |
| Do all corridors used by visitors have enough room for reasonable | No, poor access in lower KS2 |
| passage? | |
| IN THE CLASSROOM | Result and Recommendation |
| Is the door wide enough for a wheelchair? | All essential doors |
| Are the spaces into which the door opens unobstructed? | Yes |
| Is there level access into the room? | Yes |
| If 'no', could access to the room be made easier? e.g. a ramp, wider door. | |
| Library – are books easily accessible? | Yes. |
| Is there a selection of "large print" books? | No |
| CHAIRS, TABLES AND DESKS | Result and Recommendation |
| Could a wheelchair-user use the desks/ workstations? | Yes |
| Could a wheelchair-user move between the desks/ workstations? | KS2 classrooms over crowded |
| If storage is required for mobility equipment, is this adequate? | No |
| Are there any chairs/seats with arms for those requiring extra upper body | Yes, for adults. None currently for children. |
| support? | |
| TOILETS | Result and Recommendation |
| Is there a designated and properly equipped accessible toilet in the | Yes. However it is situated in entrance hall and requires non |
| building? | wheelchair user to open security button |
| If 'yes,' is the facility adequate? | Yes |
| If 'yes,' is there clear access for users? e.g. not used for storage | Yes |
| If 'yes,' are emergency and lighting cords easily distinguished? | Yes |
| If there is no accessible toilet, is there one that could be used by a | Children's toilet accessed through narrow doors |
| wheelchair user? | |
| (220cm long x 160cm wide) | |
| EMERGENCY ACCESS / EXIT | Result and Recommendation |
| Are emergency exits clearly indicated? | Yes |
| Are fire escapes for use by people with disabilities? | Not all classrooms |
| Are emergency procedures made clear to all? | Yes. As a matter of course during fire drills. |
| STAFF EXPERTISE | Result and Recommendation |
| Is there a member of staff with teaching hearing impaired qualification? | No |
| Is there a member of staff with teaching sight impaired qualification? | No |
| Is there a member of staff with supporting physical impairment | No |
| qualification? | |

| ACCESS TO INFORMATION | Result and Recommendation |
|--|--|
| Is there an availability of written material in alternative formats? | The school website meets accessibility requirements Letters can be translated into different languages if required There is as yet no provision for information to be produced in braille, though large print can be provided upon request. |
| STAFF TRAINING | |
| Is Training provided in 'Awareness Raising of Disability Issues?' | Not at present Governors, staff & pupils to receive training |

Should a person with impaired mobility, hearing or vision require regular access to or within the school the Governors will review provision and suitable arrangements will be made within current budget limitations.

A member of staff with necessary expertise will be appointed if required, depending on budgetary limitations.

Points of Notice

- Lower Key Stage 2 classrooms are undersized, emergency doors too narrow for wheelchair access.
- Upper Key Stage 2 emergency exit involve turn on exit that would impair movement of wheelchair.
- Access to parts of KS2 block limited for wheelchair users due to limited space

Cost for these alterations would be outside school's budgetary limitations.

Advice from Local Authority will be sought in order to ensure school is as accessible as possible.